Faldes











PLATE EXCHANGER

Polymeric membrane counter-flow ERV

CASING (Standard)

Material: 24-gauge galvanized steel

Drain connections: none Duct connections: 5" (127 mm)

Insulation: Polystyrene Length: 32-1/8" (816 mm) Height: 9-7/8" (251 mm) Width: 23-1/8" (587 mm) Weight: 53 lbs (24kg)

Exhaust Damper: Closed by gravity Fresh air Damper: Motorized



MOUNTING (Standard)

Ceiling mounting bracket included Mounting chains optional



ELECTRICAL & CONTROLS (Standard)

120 VAC, 60 HZ, 155 W, 2.46 A



FILTERS (Standard)

Quantity: 1 supply, 1 exhaust

Supply Filter Type: Washable MERV 8 (P/N 607116) Exhaust Filter Type: Washable Foam (P/N 609630)

(Optional: Sold Seperatetly)

MERV 13 Filters (substitute on supply air circuit only)

P/N: 607117



BLOWERS & MOTORS

Two motorized impellers (foward-curved) Auto-balancing EC motors

InspirAIR® FRESH

EK120-HRX-N

117 CFM at 0.4 in.w.g













UNIT

CORE

FROST PREVENTION/CONTROL

Automatic Timed Recirculation: Cycles are controlled by a temperature sensor when the outside temperature drops below 14°F (-10°C).

WARRANTY

Limited 5 years on the cores and all covered components.

WALL CONTROLS

Low voltage dry contact (24VAC) for interlock with heating and cooling systems.



Digital Multifunction Control (#611242-FC)



LCD Electronic Multifunction Control (P/N 611227)



20/40/60 Minute Timer (P/N 611228)




Speed Control (Low/Intermittent/High) (P/N 611229)




Mode Control (Recirculation) (P/N 611230)

Page 2 | EK120-HRX-N



EK120-HRX: PERFORMANCE



Thermal Performance – EK120-HRX-N								
Supply Tem- perature		Net Airflow		Power Consu- med	Sensible Recovery	Adjusted Sensible	Latent Recovery/	Total Recovery
°F	°C	CFM	L/s	(w)	Efficiency	Recovery Efficiency	Moisture Transfer	Efficiency
Heating								
32	0	50	23	27	76%	79%	73%	
32	0	64	30	33	75%	78%	72%	
-13	-25	66	31	62	60%	65%	65%	
Cooling								
95	35	52	24	31			79%	73%

Project:	Architect:
Location:	Engineer:
Model #:	Contractor:
Quantity:	Comments:
Submitted By:	
Date:	





